

**MUSCOGEE COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION  
PUBLIC SWIMMING POOL INSPECTION RECORD**

<b>Name of Facility</b> ECONO LODGE POOL	<b>Address</b> 4483 VICTORY DR	<b>City</b> COLUMBUS	<b>County</b>	<input checked="" type="checkbox"/> <b>SATISFACTORY</b> <input type="checkbox"/> <b>UNSATISFACTORY</b>											
<b>Operator</b> Valley Hospitality	<b>Address</b> 7270 NORTHLAKE DR	<b>City</b> COLUMBUS	<b>County</b>												
<b>Deficiencies found on the inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance. Each blank under column (24-26) should be filled in with above symbols as appropriate.</b>				<b>ENFORCEMENT</b> <input checked="" type="checkbox"/> None <input type="checkbox"/> Permit Suspended <input type="checkbox"/> Closed Voluntarily <input type="checkbox"/> Re-inspection needed within days <input type="checkbox"/> Hearing Requested/ <input type="checkbox"/> Recommended  <b>Permit No.</b> <div style="border: 1px solid black; padding: 2px; width: fit-content; margin: 5px auto;">106-P24</div> <b>Expiration Date</b> <table border="1" style="border-collapse: collapse; text-align: center; margin: 5px auto;"> <tr> <td style="width: 30px;">2012</td> <td style="width: 30px;">12</td> <td style="width: 30px;">31</td> </tr> </table> <p align="center">YR MO DA</p> <b>Purpose</b> <table border="1" style="border-collapse: collapse; text-align: center; margin: 5px auto;"> <tr> <td style="width: 30px;">1</td> <td style="width: 100px;">           1. Routine            2. Re-inspection            3. Request            4. Complaint            5. Other         </td> </tr> </table> Length of Inspection <u>00:00</u> Hours  <b>Pool Type:</b> <input checked="" type="checkbox"/> Swimming/Pool <input type="checkbox"/> Spa <input type="checkbox"/> Special Purpose Pool: Activity/Interactive/Wading Type: Pool  Required Turnover Rate: <u>0.00</u> gpm Type of Disinfection: _____ Required Concentration: _____  <table border="1" style="border-collapse: collapse; text-align: center; margin: 5px auto;"> <tr> <td style="width: 30px;"> </td> <td style="width: 30px;"> </td> <td style="width: 30px;">3</td> <td style="width: 30px;">5</td> </tr> </table> <p align="center">Bather Load</p> <b>Purpose</b> <table border="1" style="border-collapse: collapse; text-align: center; margin: 5px auto;"> <tr> <td style="width: 30px;"> </td> <td style="width: 100px;">           1. None            2. Water            3. Other         </td> </tr> </table> Reason for Sample: _____	2012	12	31	1	1. Routine 2. Re-inspection 3. Request 4. Complaint 5. Other			3	5		1. None 2. Water 3. Other
2012	12	31													
1	1. Routine 2. Re-inspection 3. Request 4. Complaint 5. Other														
		3	5												
	1. None 2. Water 3. Other														
<b>POOL WATER</b>	Type supply: Public	Item No.	24-59		Notes										
	Water supply approved, adequate	1	✓												
	Depth properly marked	2	✓												
	Overflow facilities adequate	3	✓												
	Constant water level	4	✓												
	Turnover adequate	5	✓		(see addendum)										
	Disinfectant residual concentration	6	✓		(see addendum)										
	pH (7.2-7.8)	7	✓		(see addendum)										
	Total Alkalinity	8	✓		(see addendum)										
	Calcium Hardness	9	✓		(see addendum)										
	Cyanuric Acid	10	✓												
	Clarity	11	✓												
<b>PUMPING FILTRATION AND TREATMENT SYSTEM</b>	Pump operating properly	12	✓												
	Filters functioning properly	13	✓												
	Hair & lint strainers functioning properly	14	✓												
	Skimmers/Gutters maintained & operating properly	15	✓		(see addendum)										
	Chemical feeders operating properly	16	✓												
	Recirculation and filtration equipment readily accessible	17	✓												
<b>DECK AND POOL AREA</b>	Pool & Decks clean and in good repair	18	✓												
	Night lighting adequate	19	✓												
<b>WATER AND FACILITIES</b>	Hot & cold water under pressure	20	✓												
	Adequate toilet facilities & showers	21	✓												
<b>SEWAGE DISPOSAL</b>	Sewage disposal method: Public	22	✓												
<b>SAFETY PRE-CAUTIONS</b>	Life line in place/Separation of wading pool	23	✓												
	Warning/Safety sign posted in clearview of pool area	24	✓												
	First aid kits available & properly equipped	25	✓												
	Emergency & lifesaving equipment in conspicuous place	26	✓												
	Emergency phone provided and hard wired	27	✓												
	Gas cylinder precautions adequate	28	✓		(see addendum)										
	Proper barrier around pool	29	✓												
	Main drains properly covered and maintained	30	✓												
<b>OPERATOR AND RECORDS</b>	Certified Pool Operator	31													
	Lifeguard(s) (if provided) has proper certification	32	✓	(see addendum)											
	Trained operator on duty	33	✓												
	Appropriate records on file	34	✓												
	Pool test kit(s) available and adequate for all necessary tests	35	✓												
	Other	36	✓												
<b>Gauge Readings:</b>		<b>Laboratory Results:</b>													
Influent Pressure	0.00 psi	Alkalinity	0.00 ppm												
Effluent Pressure	0.00 psi	Coliform Count	0.00												
Flow Rate Main Pool	0.00 gpm	Plate Count	0.00												
Flow Rate Wading Pool	0.00 gpm														
Name of Bactericide In Use: <u>Salt / Chlorine</u>		Rate	0.00 ppm												
Name of Stabilizer In Use:		Rate	0.00 ppm												
Name of Filter System In Use:															
Algae Control Measures:															
<b>Remarks</b>															
<b>Date of Inspection</b> 08/17/2011	<b>Discussed with (Signature)</b>  Cindy Ratchel Title: GM		<b>Inspected by (Signature)</b>  Jason Long Title: Environmental Health Specialist II												

**MUSCOGEE COUNTY HEALTH DEPARTMENT  
 ENVIRONMENTAL HEALTH SECTION  
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

<b>Name of Facility</b> ECONO LODGE POOL	<b>Address</b> 4483 VICTORY DR	<b>City</b> COLUMBUS	<b>County</b>
<b>Operator</b> Valley Hospitality	<b>Address</b> 7270 NORTHLAKE DR	<b>City</b> COLUMBUS	<b>County</b>

Item Number	Notes
5	55
6	3.0
7	7.6
8	110
9	90
15	Missing 1 wier gate
28	n/a
32	n/a