

**MUSCOGEE COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
PUBLIC SWIMMING POOL INSPECTION RECORD**

Name of Facility QUALITY INN POOL		Address 1325 VETERANS PKWY	City COLUMBUS	County	<input checked="" type="checkbox"/> SATISFACTORY <input type="checkbox"/> UNSATISFACTORY														
Operator Lyra B. Watkins		Address 1325 VETERANS PKWY	City COLUMBUS	County															
Deficiencies found on the inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance. Each blank under column (24-26) should be filled in with above symbols as appropriate.					ENFORCEMENT <input checked="" type="checkbox"/> None <input type="checkbox"/> Permit Suspended <input type="checkbox"/> Closed Voluntarily <input type="checkbox"/> Re-inspection needed within days <input type="checkbox"/> Hearing Requested/Recommended Permit No. <div style="border: 1px solid black; padding: 2px; width: fit-content;">106-P26</div> Expiration Date <table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td style="width: 30px; text-align: center;">2014</td> <td style="width: 30px; text-align: center;">12</td> <td style="width: 30px; text-align: center;">31</td> </tr> <tr> <td align="center" colspan="3">YR MO DA</td> </tr> </table> Purpose <table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td style="width: 30px; text-align: center;">1</td> </tr> </table> <ol style="list-style-type: none"> 1. Routine 2. Re-inspection 3. Request 4. Complaint 5. Other Length of Inspection <u>00:35</u> Hours Pool Type: <input checked="" type="checkbox"/> Swimming/Pool <input type="checkbox"/> Spa Special Purpose Pool: Activity/Interactive/Wading Type: <u>Pool</u> Required Turnover Rate: <u>58.00</u> gpm Type of Disinfection: <u>Trichlor</u> Required Concentration: <u>3.0</u> <table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td style="width: 30px;"></td> <td style="width: 30px; text-align: center;">3</td> <td style="width: 30px; text-align: center;">9</td> </tr> <tr> <td align="center" colspan="3">Bather Load</td> </tr> </table> Purpose <table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td style="width: 30px; text-align: center;">1</td> </tr> </table> <ol style="list-style-type: none"> 1. None 2. Water 3. Other Reason for Sample:	2014	12	31	YR MO DA			1		3	9	Bather Load			1
2014	12	31																	
YR MO DA																			
1																			
	3	9																	
Bather Load																			
1																			
		Item No.	24-59	Notes															
POOL WATER	Type supply: Public																		
	Water supply approved, adequate	1	✓																
	Depth properly marked	2	X	(see addendum)															
	Overflow facilities adequate	3	✓																
	Constant water level	4	✓																
	Turnover adequate	5	✓	(see addendum)															
	Disinfectant residual concentration	6	✓	(see addendum)															
	pH (7.2-7.8)	7	✓	(see addendum)															
	Total Alkalinity	8	✓	(see addendum)															
	Calcium Hardness	9	✓	(see addendum)															
	Cyanuric Acid	10	✓	(see addendum)															
Clarity	11	✓																	
PUMPING FILTRATION AND TREATMENT SYSTEM	Pump operating properly	12	✓																
	Filters functioning properly	13	✓																
	Hair & lint strainers functioning properly	14	✓																
	Skimmers/Gutters maintained & operating properly	15	✓																
	Chemical feeders operating properly	16	✓																
	Recirculation and filtration equipment readily accessible	17	✓																
	DECK AND POOL AREA	Pool & Decks clean and in good repair	18	✓															
Night lighting adequate		19	✓	(see addendum)															
WATER AND FACILITIES	Hot & cold water under pressure	20	✓																
	Adequate toilet facilities & showers	21	✓	(see addendum)															
SEWAGE DISPOSAL	Sewage disposal method: Public	22	✓																
SAFETY PRE-CAUTIONS	Life line in place/Separation of wading pool	23	✓	(see addendum)															
	Warning/Safety sign posted in clearview of pool area	24	✓																
	First aid kits available & properly equipped	25	✓	(see addendum)															
	Emergency & lifesaving equipment in conspicuous place	26	✓																
	Emergency phone provided and hard wired	27	✓	(see addendum)															
	Gas cylinder precautions adequate	28	✓	(see addendum)															
	Proper barrier around pool	29	✓																
	Main drains properly covered and maintained	30	✓																
	OPERATOR AND RECORDS	Certified Pool Operator	31		(see addendum)														
Lifeguard(s) (if provided) has proper certification		32	✓	(see addendum)															
Trained operator on duty		33	✓	(see addendum)															
Appropriate records on file		34	✓																
Pool test kit(s) available and adequate for all necessary tests		35	✓																
Other		36	✓	(see addendum)															
Gauge Readings:		Laboratory Results:																	
Influent Pressure	<u>0.00</u> psi	Alkalinity	<u>0.00</u> ppm																
Effluent Pressure	<u>0.00</u> psi	Coliform Count	<u>0.00</u>																
Flow Rate Main Pool	<u>0.00</u> gpm	Plate Count	<u>0.00</u>																
Flow Rate Wading Pool	<u>0.00</u> gpm																		
Name of Bactericide In Use: <u>Trichlor</u>		Rate	<u>0.00</u> ppm																
Name of Stabilizer In Use:		Rate	<u>0.00</u> ppm																
Name of Filter System In Use:																			
Algae Control Measures:																			
Remarks Before permitting for 2012 season, depth markers must be placed on vertical walls of pool.																			
Date of Inspection 07/11/2011	Discussed with (Signature) Edward Long Title: Maintenance		Inspected by (Signature) Kristi Ludy Title: Environmental Health Specialist III																

**MUSCOGEE COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH SECTION
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

Name of Facility QUALITY INN POOL	Address 1325 VETERANS PKWY	City COLUMBUS	County
Operator Lyra B. Watkins	Address 1325 VETERANS PKWY	City COLUMBUS	County

Item Number	Notes
2	Depth markers missing on vertical walls of pool.
5	60 gpm
6	10.0
7	7.2
8	140
9	NA
10	NA
19	NA - Swimming at night not allowed.
21	Adjacent lobby and hotel rooms.
23	NA - 5ft and less
25	Located at front desk
27	Rings to 911 sevice.
28	NA
31	Lyra Watkins
32	NA - No lifeguard on duty.
33	Edward Long
36	Water Fountain present on deck.