

**MUSCOGEE COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
PUBLIC SWIMMING POOL INSPECTION RECORD**

Name of Facility COURTYARD BY MARRIOTT POOL	Address 3501 COURTYARD WAY	City COLUMBUS	County
Operator Chris Smith	Address ONE MARRIOTT DR	City WASHINGTON	County

SATISFACTORY
 UNSATISFACTORY

ENFORCEMENT
 None
 Permit Suspended
 Closed Voluntarily
 Re-inspection needed within days
 Hearing Requested/Recommended

Deficiencies found on the inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance. Each blank under column (24-26) should be filled in with above symbols as appropriate.

		Item No.	24-59	Notes
POOL WATER	Type supply: Public			
	Water supply approved, adequate	1	✓	
	Depth properly marked	2	✓	
	Overflow facilities adequate	3	✓	
	Constant water level	4	✓	
	Turnover adequate	5	✓	(see addendum)
	Disinfectant residual concentration	6	✓	(see addendum)
	pH (7.2-7.8)	7	✓	(see addendum)
	Total Alkalinity	8	✓	(see addendum)
	Calcium Hardness	9	✓	(see addendum)
	Cyanuric Acid	10	✓	(see addendum)
Clarity	11	✓		
PUMPING FILTRATION AND TREATMENT SYSTEM	Pump operating properly	12	✓	
	Filters functioning properly	13	✓	
	Hair & lint strainers functioning properly	14	✓	
	Skimmers/Gutters maintained & operating properly	15	✓	
	Chemical feeders operating properly	16	✓	
	Recirculation and filtration equipment readily accessible	17	✓	
	DECK AND POOL AREA	Pool & Decks clean and in good repair	18	✓
Night lighting adequate		19	✓	(see addendum)
WATER AND FACILITIES	Hot & cold water under pressure	20	✓	(see addendum)
	Adequate toilet facilities & showers	21	✓	(see addendum)
SEWAGE DISPOSAL	Sewage disposal method: Public	22	✓	
SAFETY PRE-CAUTIONS	Life line in place/Separation of wading pool	23	✓	(see addendum)
	Warning/Safety sign posted in clearview of pool area	24	✓	
	First aid kits available & properly equipped	25	✓	(see addendum)
	Emergency & lifesaving equipment in conspicuous place	26	✓	
	Emergency phone provided and hard wired	27	✓	(see addendum)
	Gas cylinder precautions adequate	28	✓	(see addendum)
	Proper barrier around pool	29	✓	
	Main drains properly covered and maintained	30	✓	
	OPERATOR AND RECORDS	Certified Pool Operator	31	
Lifeguard(s) (if provided) has proper certification		32	✓	(see addendum)
Trained operator on duty		33	✓	(see addendum)
Appropriate records on file		34	✓	
Pool test kit(s) available and adequate for all necessary tests		35	✓	
Other		36	✓	(see addendum)

Permit No.
106-P28

Expiration Date
2012 12 31
YR MO DA

Purpose
 1. Routine
 2. Re-inspection
 3. Request
 4. Complaint
 5. Other

Length of Inspection 01:05 Hours

Pool Type:
 Swimming/Pool
 Spa
 Special Purpose Pool:
 Activity/Interactive/Wading
 Type: Pool

Required Turnover Rate: 55.00gpm
 Type of Disinfection: Cal Hypo
 Required Concentration: 1.5

Bather Load
5 0

Purpose
 1. None
 2. Water
 3. Other

Reason for Sample:

Gauge Readings:	Laboratory Results:
Influent Pressure 0.00 psi	Alkalinity 0.00 ppm
Effluent Pressure 0.00 psi	Coliform Count 0.00
Flow Rate Main Pool 0.00 gpm	Plate Count 0.00
Flow Rate Wading Pool 0.00 gpm	
Name of Bactericide In Use: Cal Hypo	Rate 0.00 ppm
Name of Stabilizer In Use:	Rate 0.00 ppm
Name of Filter System In Use:	
Algae Control Measures:	

Remarks

Date of Inspection 07/18/2011	Discussed with (Signature) David C. Smith Title: Chief Engineer	Inspected by (Signature) Kristi Ludy Title: Environmental Health Specialist III
---	--	--

**MUSCOGEE COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH SECTION
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

Name of Facility COURTYARD BY MARRIOTT POOL		Address 3501 COURTYARD WAY	City COLUMBUS	County
Operator Chris Smith		Address ONE MARRIOTT DR	City WASHINGTON	County

Item Number	Notes
5	110 gpm
6	4.0
7	7.2
8	160
9	NA
10	NA
19	Pool Hours 7am-11pm
20	Located in lobby and adjacent hotel rooms.
21	Located in lobby and adjacent hotel rooms
23	NA - 5 feet and less
25	Located at front desk and pump room.
27	Dial Tone then Dial 911.
28	NA
31	Chris Smith
32	NA - No lifeguard on duty
33	Rodney Paton
36	water fountain