

**MUSCOGEE COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
PUBLIC SWIMMING POOL INSPECTION RECORD**

Name of Facility COLUMBUS MARRIOTT POOL	Address 800 FRONT AVE	City COLUMBUS	County
Operator Eddie Meadows	Address 600 BROOKSTONE CENTRE	City COLUMBUS	County

SATISFACTORY
 UNSATISFACTORY

ENFORCEMENT
 None
Permit Suspended
Closed Voluntarily
Re-inspection needed within days
Hearing Requested/Recommended

Deficiencies found on the inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance. Each blank under column (24-26) should be filled in with above symbols as appropriate.

	Item No.	24-59	Notes
POOL WATER	Type supply: Public		
	Water supply approved, adequate	1	✓
	Depth properly marked	2	✓
	Overflow facilities adequate	3	✓
	Constant water level	4	✓
	Turnover adequate	5	✓ (see addendum)
	Disinfectant residual concentration	6	✓ (see addendum)
	pH (7.2-7.8)	7	✓ (see addendum)
	Total Alkalinity	8	✓ (see addendum)
	Calcium Hardness	9	✓ (see addendum)
	Cyanuric Acid	10	✓ (see addendum)
Clarity	11	✓	
PUMPING FILTRATION AND TREATMENT SYSTEM	Pump operating properly	12	✓
	Filters functioning properly	13	✓
	Hair & lint strainers functioning properly	14	✓
	Skimmers/Gutters maintained & operating properly	15	✓
	Chemical feeders operating properly	16	✓
	Recirculation and filtration equipment readily accessible	17	✓
DECK AND POOL AREA	Pool & Decks clean and in good repair	18	✓
	Night lighting adequate	19	✓ (see addendum)
WATER AND FACILITIES	Hot & cold water under pressure	20	✓ (see addendum)
	Adequate toilet facilities & showers	21	✓ (see addendum)
SEWAGE DISPOSAL	Sewage disposal method: Public	22	✓
SAFETY PRE-CAUTIONS	Life line in place/Separation of wading pool	23	✓
	Warning/Safety sign posted in clearview of pool area	24	✓
	First aid kits available & properly equipped	25	✓ (see addendum)
	Emergency & lifesaving equipment in conspicuous place	26	✓
	Emergency phone provided and hard wired	27	✓ (see addendum)
	Gas cylinder precautions adequate	28	✓ (see addendum)
	Proper barrier around pool	29	✓
	Main drains properly covered and maintained	30	✓
OPERATOR AND RECORDS	Certified Pool Operator	31	(see addendum)
	Lifeguard(s) (if provided) has proper certification	32	✓ (see addendum)
	Trained operator on duty	33	✓ (see addendum)
	Appropriate records on file	34	✓
	Pool test kit(s) available and adequate for all necessary tests	35	✓
	Other	36	✓ (see addendum)

Permit No.
106-P30

Expiration Date
2012 12 31
YR MO DA

Purpose
1
1. Routine
2. Re-inspection
3. Request
4. Complaint
5. Other

Length of Inspection 00:45 Hours

Pool Type:
 Swimming/Pool
Spa
Special Purpose Pool:
Activity/Interactive/Wading
Type: Pool

Required Turnover Rate: 56.00gpm
Type of Disinfection: salt
Required Concentration: 1.5

Bather Load
5 3

Purpose
1
1. None
2. Water
3. Other

Gauge Readings:	Laboratory Results:
Influent Pressure 0.00 psi	Alkalinity 0.00 ppm
Effluent Pressure 0.00 psi	Coliform Count 0.00
Flow Rate Main Pool 0.00 gpm	Plate Count 0.00
Flow Rate Wading Pool 0.00 gpm	
Name of Bactericide In Use: salt	Rate 0.00 ppm
Name of Stabilizer In Use:	Rate 0.00 ppm
Name of Filter System In Use:	
Algae Control Measures:	

Reason for Sample:

Remarks

Date of Inspection 07/19/2011	Discussed with (Signature) Edmund Peabody Title: Maintenance Manager	Inspected by (Signature) Kristi Ludy Title: Environmental Health Specialist III
---	---	--

**MUSCOGEE COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH SECTION
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

Name of Facility COLUMBUS MARRIOTT POOL	Address 800 FRONT AVE	City COLUMBUS	County
Operator Eddie Meadows	Address 600 BROOKSTONE CENTRE	City COLUMBUS	County

Item Number	Notes
5	80 gpm
6	1.5
7	7.8
8	90
9	NA
10	NA
19	Pool Hours 6am-11pm
20	Located in adjacent hotel rooms.
21	Located in lobby and adjacent hotel rooms.
25	Located at front desk.
27	Dials directly to 911.
28	NA
31	Eddie Meadows
32	NA - No lifeguard on duty.
33	Edmund Peabody
36	water fountain