

MUSCOGEE COUNTY HEALTH DEPARTMENT  
 ENVIRONMENTAL HEALTH SECTION  
 PUBLIC SWIMMING POOL INSPECTION RECORD

Name of Facility Holiday Inn Express		Address 3901 Victory DR	City COLUMBUS	County
Operator		Address 3901 Victory DR	City COLUMBUS	County
Deficiencies found on the inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance. Each blank under column (24-26) should be filled in with above symbols as appropriate.				
		Item No.	24-59	Notes
<b>POOL WATER</b>	Type supply: Public			
	Water supply approved, adequate	1	✓	
	Depth properly marked	2	✓	
	Overflow facilities adequate	3	✓	
	Constant water level	4	✓	
	Turnover adequate	5	✓	(see addendum)
	Disinfectant residual concentration	6	✓	(see addendum)
	pH (7.2-7.8)	7	✓	(see addendum)
	Total Alkalinity	8	✓	(see addendum)
	Calcium Hardness	9	✓	(see addendum)
	Cyanuric Acid	10	✓	
Clarity	11	✓		
<b>PUMPING FILTRATION AND TREATMENT SYSTEM</b>	Pump operating properly	12	✓	
	Filters functioning properly	13	✓	
	Hair & lint strainers functioning properly	14	✓	
	Skimmers/Gutters maintained & operating properly	15	X	(see addendum)
	Chemical feeders operating properly	16	✓	
	Recirculation and filtration equipment readily accessible	17	✓	
<b>DECK AND POOL AREA</b>	Pool & Decks clean and in good repair	18	✓	
	Night lighting adequate	19	✓	
<b>WATER AND FACILITIES</b>	Hot & cold water under pressure	20	✓	
	Adequate toilet facilities & showers	21	✓	
<b>SEWAGE DISPOSAL</b>	Sewage disposal method: Public	22	✓	
<b>SAFETY PRE-CAUTIONS</b>	Life line in place/Separation of wading pool	23	✓	
	Warning/Safety sign posted in clearview of pool area	24	✓	
	First aid kits available & properly equipped	25	✓	
	Emergency & lifesaving equipment in conspicuous place	26	✓	
	Emergency phone provided and hard wired	27	✓	
	Gas cylinder precautions adequate	28	✓	(see addendum)
	Proper barrier around pool	29	✓	
	Main drains properly covered and maintained	30	✓	
<b>OPERATOR AND RECORDS</b>	Certified Pool Operator	31		
	Lifeguard(s) (if provided) has proper certification	32	✓	
	Trained operator on duty	33	✓	
	Appropriate records on file	34	✓	
	Pool test kit(s) available and adequate for all necessary tests	35	✓	
	Other	36	✓	
<b>Gauge Readings:</b>		<b>Laboratory Results:</b>		
Influent Pressure	0.00 psi	Alkalinity	0.00 ppm	
Effluent Pressure	0.00 psi	Coliform Count	0.00	
Flow Rate Main Pool	0.00 gpm	Plate Count	0.00	
Flow Rate Wading Pool	0.00 gpm			
Name of Bactericide In Use: Trichlor		Rate	0.00 ppm	
Name of Stabilizer In Use:		Rate	0.00 ppm	
Name of Filter System In Use:				
Algae Control Measures:				
Remarks				
Date of Inspection 08/17/2011	Discussed with (Signature)  Alex Miquel Title: Owner		Inspected by (Signature)  Jason Long Title: Environmental Health Specialist II	

✓SATISFACTORY  
 UNSATISFACTORY

**ENFORCEMENT**

- ✓ None
- Permit Suspended
- Closed Voluntarily
- Re-inspection needed within days
- Hearing Requested/Recommended

**Permit No.**

SPP-106-000004

**Expiration Date**

2013 12 30  
 YR MO DA

**Purpose**

- 1. Routine
- 2. Re-inspection
- 3. Request
- 4. Complaint
- 5. Other

Length of Inspection 00:45 Hours

**Pool Type:**

- ✓ Swimming/Pool
- Spa
- Special Purpose Pool: Activity/Interactive/Wading
- Type: Pool

Required Turnover Rate: 0.00 gpm

Type of Disinfection:

Required Concentration:

4 2  
 Bather Load

**Purpose**

- 1. None
- 2. Water
- 3. Other

Reason for Sample:

**MUSCOGEE COUNTY HEALTH DEPARTMENT  
 ENVIRONMENTAL HEALTH SECTION  
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

<b>Name of Facility</b>	<b>Address</b>	<b>City</b>	<b>County</b>
Holiday Inn Express	3901 Victory DR	COLUMBUS	
<b>Operator</b>	<b>Address</b>	<b>City</b>	<b>County</b>
	3901 Victory DR	COLUMBUS	
<b>Item Number</b>	<b>Notes</b>		
5	105		
6	10		
7	7.2		
8	80		
9	90		
15	Missing 1 wier gate		
28	n/a		