

**MUSCOGEE COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION  
PUBLIC SWIMMING POOL INSPECTION RECORD**

<b>Name of Facility</b> HOWARD JOHNSON POOL	<b>Address</b> 1011 VETERANS PKWY	<b>City</b> COLUMBUS	<b>County</b>
<b>Operator</b> Arnold E. Meadows	<b>Address</b> NO RECORD	<b>City</b>	<b>County</b>

**SATISFACTORY**  
 **UNSATISFACTORY**

Deficiencies found on the inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance. Each blank under column (24-26) should be filled in with above symbols as appropriate.

	Item No.	24-59	Notes
<b>POOL WATER</b>	Type supply: Public		
	Water supply approved, adequate	1	✓
	Depth properly marked	2	✓ (see addendum)
	Overflow facilities adequate	3	✓
	Constant water level	4	✓
	Turnover adequate	5	✓ (see addendum)
	Disinfectant residual concentration	6	✓ (see addendum)
	pH (7.2-7.8)	7	✓ (see addendum)
	Total Alkalinity	8	✓ (see addendum)
	Calcium Hardness	9	✓ (see addendum)
	Cyanuric Acid	10	✓ (see addendum)
<b>PUMPING FILTRATION AND TREATMENT SYSTEM</b>	Clarity	11	✓
	Pump operating properly	12	✓
	Filters functioning properly	13	✓
	Hair & lint strainers functioning properly	14	✓
	Skimmers/Gutters maintained & operating properly	15	✓
	Chemical feeders operating properly	16	✓
	Recirculation and filtration equipment readily accessible	17	✓
<b>DECK AND POOL AREA</b>	Pool & Decks clean and in good repair	18	✓
	Night lighting adequate	19	✓ (see addendum)
<b>WATER AND FACILITIES</b>	Hot & cold water under pressure	20	✓ (see addendum)
	Adequate toilet facilities & showers	21	✓ (see addendum)
<b>SEWAGE DISPOSAL</b>	Sewage disposal method: Public	22	✓
<b>SAFETY PRE-CAUTIONS</b>	Life line in place/Separation of wading pool	23	✓
	Warning/Safety sign posted in clearview of pool area	24	✓
	First aid kits available & properly equipped	25	✓ (see addendum)
	Emergency & lifesaving equipment in conspicuous place	26	✓
	Emergency phone provided and hard wired	27	✓ (see addendum)
	Gas cylinder precautions adequate	28	✓ (see addendum)
	Proper barrier around pool	29	✓
	Main drains properly covered and maintained	30	✓ (see addendum)
	<b>OPERATOR AND RECORDS</b>	Certified Pool Operator	31
Lifeguard(s) (if provided) has proper certification		32	✓ (see addendum)
Trained operator on duty		33	✓ (see addendum)
Appropriate records on file		34	✓
Pool test kit(s) available and adequate for all necessary tests		35	✓
Other		36	✓ (see addendum)

**ENFORCEMENT**  
 None  
 Permit Suspended  
 Closed Voluntarily  
 Re-inspection needed within days  
 Hearing Requested/Recommended

**Permit No.**  

106-P44

**Expiration Date**  

2012	12	31
------	----	----

  
 YR MO DA

**Purpose**  

1

1. Routine
2. Re-inspection
3. Request
4. Complaint
5. Other

Length of Inspection 00:35 Hours

**Pool Type:**  
 Swimming/Pool  
 Spa  
 Special Purpose Pool:  
     Activity/Interactive/Wading  
 Type: Pool

Required Turnover Rate: 90.00 gpm  
 Type of Disinfection: salt  
 Required Concentration: 1.5

		3	9
--	--	---	---

  
 Bather Load

**Purpose**  

1

1. None
2. Water
3. Other

Reason for Sample:

Gauge Readings:		Laboratory Results:	
Influent Pressure	<u>0.00</u> psi	Alkalinity	<u>0.00</u> ppm
Effluent Pressure	<u>0.00</u> psi	Coliform Count	<u>0.00</u>
Flow Rate Main Pool	<u>0.00</u> gpm	Plate Count	<u>0.00</u>
Flow Rate Wading Pool	<u>0.00</u> gpm		
Name of Bactericide In Use:	<u>salt</u>	Rate	<u>0.00</u> ppm
Name of Stabilizer In Use:		Rate	<u>0.00</u> ppm
Name of Filter System In Use:			
Algae Control Measures:			

**Remarks**  
 Before permitting for 2012 season, vertical depth markers (3 ft) must be placed on walls of pool.

<b>Date of Inspection</b> 07/11/2011	<b>Discussed with (Signature)</b>  Arnold E. Meadows Title: CPO	<b>Inspected by (Signature)</b>  Kristi Ludy Title: Environmental Health Specialist III
-----------------------------------------	--------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------

**MUSCOGEE COUNTY HEALTH DEPARTMENT  
 ENVIRONMENTAL HEALTH SECTION  
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

<b>Name of Facility</b> HOWARD JOHNSON POOL	<b>Address</b> 1011 VETERANS PKWY	<b>City</b> COLUMBUS	<b>County</b>
<b>Operator</b> Arnold E. Meadows	<b>Address</b> NO RECORD	<b>City</b>	<b>County</b>

Item Number	Notes
2	Depth markers at 3 ft missing on vertical walls of pool.
5	>140 gpm
6	1.5
7	7.4
8	100
9	NA
10	NA
19	Pool Hours 10:00 am - 10:00 pm
20	Located in adjacent lobby and hotel rooms.
21	Located in adjacent lobby and hotel rooms.
25	Located in maintenance shop and lobby.
27	Directly dials 911.
28	NA
30	NA Main drain does not exist.
31	Eddie Meadows
32	No lifeguard on duty.
33	Mark Foster
36	water fountain