


**Georgia Department of Public Health  
PUBLIC SWIMMING POOL INSPECTION RECORD**

Name of Facility COMFORT INN POOL		Address 3460 MACON RD	City COLUMBUS	County
Certified Pool Operator Charlie Desai		Address 3460 MACON RD	City COLUMBUS	County
<p>Deficiencies found on the inspection are marked with a (X). A check mark (✓) indicates satisfactory compliance, and (N/A) means non-applicable. *Indicates a substantial health hazard. Other items may be considered substantial health hazards depending on severity. The pool must be closed until substantial health hazards are corrected. One or more substantial health hazards violated, two or more other items violated or repeated violations will result in an unsatisfactory rating. An unsatisfactory rating may result in enforcement action.</p>				
		X/✓	Notes	
POOL WATER	1. Water supply approved, adequate	✓		
	2. Depth properly marked	✓		
	3. Overflow facilities adequate	✓		
	4. Constant water level	✓		
	5. Turnover adequate	✓	(see addendum)	
	6. Disinfectant residual concentration 5.0	✓	(see addendum)	
	7. pH (7.2-7.8)	✓	(see addendum)	
	8. Total Alkalinity	✓	(see addendum)	
	9. Calcium Hardness	✓	(see addendum)	
	10. Cyanuric Acid	✓		
PUMPING FILTRATION AND TREATMENT SYSTEM	11. Clarity	✓		
	12. Pump operating properly	✓		
	13. Filters functioning properly	✓		
	14. Hair & lint strainers functioning properly	✓		
	15. Skimmers/Gutters maintained & operating properly	✓		
	16. Chemical feeders operating properly	✓		
	17. Recirculation and filtration equipment readily accessible	✓		
DECK AND POOL AREA	18. Pool & Decks clean and in good repair	✓	(see addendum)	
	19. Night lighting adequate	✓		
WATER AND FACILITIES	20. Hot & cold water under pressure	✓		
SEWAGE DISPOSAL	21. Adequate toilet facilities & showers	✓	(see addendum)	
	22. Sewage disposal method: Public	✓		
SAFETY PRE-CAUTIONS	23. Life line in place/Separation of wading pool	✓		
	24. Warning/Safety sign posted in clearview of pool area	✓	(see addendum)	
	25. First aid kits available & properly equipped	✓	(see addendum)	
	26. Emergency & lifesaving equipment in conspicuous place	✓		
	27. Emergency phone provided and hard wired	✓	(see addendum)	
	28. Gas cylinder precautions adequate	✓		
	29. Proper barrier around pool	✓	(see addendum)	
	30. Main drains properly covered and maintained	✓	(see addendum)	
OPERATOR AND RECORDS	31. Certified Pool Operator			
	32. Lifeguard(s) (if provided) has proper certification	✓		
	33. Trained operator on duty	✓		
	34. Appropriate records on file	✓		
	35. Pool test kit(s) available and adequate for all necessary tests	✓		
	36. Other	✓		
Remarks <i>Pool OK To Permit</i>				
Date of Inspection 01/31/2012	Discussed with (Signature & Title)  Maintenance		Inspected by (Signature & Title)  Environmental Health Specialist IV	

**SATISFACTORY**

**UNSATISFACTORY**

**ENFORCEMENT**

None

Permit Suspended

Closed Voluntarily

Re-inspection needed within days

Hearing Requested/Recommended

Permit No.  
106-P48

Expiration Date

2011	12	31
YY MM DD		

Purpose:

1
---

1. Routine
2. Follow-up
3. Request
4. Complaint
- 5.

Other \_\_\_\_\_

Length of Inspection  
732 Minutes

Pool Type:

Swimming/Pool

Spa

Special Purpose

Pool: Activity/Interactive/Wading  
Type: Pool

Required Turnover Rate 31.00 hours

Type of Disinfectant tri clor \_\_\_\_\_

Required Concentration 5.0

Bather Load

		2	1
--	--	---	---

Laboratory Sample

1. None

2. Water

3. Other

Reason for Sample: \_\_\_\_\_

**MUSCOGEE COUNTY HEALTH DEPARTMENT  
 ENVIRONMENTAL HEALTH SECTION  
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

<b>Name of Facility</b> COMFORT INN POOL	<b>Address</b> 3460 MACON RD	<b>City</b> COLUMBUS	<b>County</b>
<b>Operator</b> Charlie Desai	<b>Address</b> 3460 MACON RD	<b>City</b> COLUMBUS	<b>County</b>

Item Number	Notes
5	41 gpm
6	5.0
7	7.2
8	160
9	180
18	inside pool
21	Toilets in lobby and in rooms
24	No diving sign at least 4 inches around deck
25	Front desk
27	dail 9 then 911
29	Must have room key to enter inside pool
30	VGB Act on file