


**Georgia Department of Public Health
PUBLIC SWIMMING POOL INSPECTION RECORD**

Name of Facility HILTON GARDEN INN POOL		Address 1500 BRADLEY LAKE BLVD		City COLUMBUS	County
Certified Pool Operator David Burris		Address 101 CASCADE RD		City COLUMBUS	County
<p>Deficiencies found on the inspection are marked with a (X). A check mark (✓) indicates satisfactory compliance, and (N/A) means non-applicable. *Indicates a substantial health hazard. Other items may be considered substantial health hazards depending on severity. The pool must be closed until substantial health hazards are corrected. One or more substantial health hazards violated, two or more other items violated or repeated violations will result in an unsatisfactory rating. An unsatisfactory rating may result in enforcement action.</p>					
		X/✓		Notes	
POOL WATER	1. Water supply approved, adequate	✓			
	2. Depth properly marked	✓			
	3. Overflow facilities adequate	✓			
	4. Constant water level	✓			
	5. Turnover adequate	✓	(see addendum)		
	6. Disinfectant residual concentration 2.0	✓	(see addendum)		
	7. pH (7.2-7.8)	✓	(see addendum)		
	8. Total Alkalinity	✓	(see addendum)		
	9. Calcium Hardness	✓			
	10. Cyanuric Acid	✓			
	11. Clarity	✓			
PUMPING FILTRATION AND TREATMENT SYSTEM	12. Pump operating properly	✓			
	13. Filters functioning properly	✓			
	14. Hair & lint strainers functioning properly	✓			
	15. Skimmers/Gutters maintained & operating properly	✓			
	16. Chemical feeders operating properly	✓			
	17. Recirculation and filtration equipment readily accessible	✓			
DECK AND POOL AREA	18. Pool & Decks clean and in good repair	✓			
	19. Night lighting adequate	✓	(see addendum)		
WATER AND FACILITIES	20. Hot & cold water under pressure	✓			
	21. Adequate toilet facilities & showers	✓	(see addendum)		
SEWAGE DISPOSAL	22. Sewage disposal method: Public	✓			
SAFETY PRE-CAUTIONS	23. Life line in place/Separation of wading pool	✓			
	24. Warning/Safety sign posted in clearview of pool area	✓			
	25. First aid kits available & properly equipped	✓	(see addendum)		
	26. Emergency & lifesaving equipment in conspicuous place	✓			
	27. Emergency phone provided and hard wired	✓	(see addendum)		
	28. Gas cylinder precautions adequate	✓			
	29. Proper barrier around pool	✓	(see addendum)		
OPERATOR AND RECORDS	30. Main drains properly covered and maintained	✓	(see addendum)		
	31. Certified Pool Operator		(see addendum)		
	32. Lifeguard(s) (if provided) has proper certification	✓			
	33. Trained operator on duty	✓			
	34. Appropriate records on file	✓			
	35. Pool test kit(s) available and adequate for all necessary tests	✓			
	36. Other	✓			
Remarks Pool ok to permit					
Date of Inspection 01/31/2012		Discussed with (Signature & Title) Maintenance		Inspected by (Signature & Title)  Environmental Health Specialist IV	

SATISFACTORY

UNSATISFACTORY

ENFORCEMENT

None

Permit Suspended

Closed Voluntarily

Re-inspection needed within days

Hearing Requested/Recommended

Permit No. 106-P57

Expiration Date

2012	12	31
YY	MM	DD

Purpose:

1

1. Routine
2. Follow-up
3. Request
4. Complaint
5.

Other _____

Length of Inspection 732 Minutes

Pool Type:

Swimming/Pool

Spa

Special Purpose

Pool: Activity/Interactive/Wading
Type: Pool

Required Turnover Rate 23.00 hours

Type of Disinfectant Cal Hypo

Required Concentration 2.0

Bather Load

3	2
---	---

Laboratory Sample

1. None
2. Water
3. Other

Reason for Sample: _____

**MUSCOGEE COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH SECTION
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

Name of Facility HILTON GARDEN INN POOL	Address 1500 BRADLEY LAKE BLVD	City COLUMBUS	County
Operator David Burris	Address 101 CASCADE RD	City COLUMBUS	County

Item Number	Notes
5	4.0
6	2.0
7	7.2
8	100
19	Inside pool
21	In rooms and lobby
25	Located at front desk
27	911
29	Must have room to enter pool area
30	VGB Act letter on file
31	David Burris