


**Georgia Department of Public Health  
PUBLIC SWIMMING POOL INSPECTION RECORD**

Name of Facility <b>HILTON GARDEN INN SPA</b>		Address 1500 BRADLEY LAKE BLVD	City COLUMBUS	County
Certified Pool Operator David Burris		Address 101 CASCADE RD	City COLUMBUS	County
<p>Deficiencies found on the inspection are marked with a (X). A check mark (✓) indicates satisfactory compliance, and (N/A) means non-applicable. *Indicates a substantial health hazard. Other items may be considered substantial health hazards depending on severity. The pool must be closed until substantial health hazards are corrected. One or more substantial health hazards violated, two or more other items violated or repeated violations will result in an unsatisfactory rating. An unsatisfactory rating may result in enforcement action.</p>				
		X/✓	Notes	
POOL WATER	1. Water supply approved, adequate	✓		
	2. Depth properly marked	✓		
	3. Overflow facilities adequate	✓		
	4. Constant water level	✓		
	5. Turnover adequate	✓	(see addendum)	
	6. Disinfectant residual concentration 6.0	✓	(see addendum)	
	7. pH (7.2-7.8)	✓	(see addendum)	
	8. Total Alkalinity	✓	(see addendum)	
	9. Calcium Hardness	✓		
	10. Cyanuric Acid	✓		
	11. Clarity	✓		
PUMPING FILTRATION AND TREATMENT SYSTEM	12. Pump operating properly	✓		
	13. Filters functioning properly	✓		
	14. Hair & lint strainers functioning properly	✓		
	15. Skimmers/Gutters maintained & operating properly	✓		
	16. Chemical feeders operating properly	✓		
	17. Recirculation and filtration equipment readily accessible	✓		
DECK AND POOL AREA	18. Pool & Decks clean and in good repair	✓		
	19. Night lighting adequate	✓		
WATER AND FACILITIES	20. Hot & cold water under pressure	✓		
	21. Adequate toilet facilities & showers	✓		
SEWAGE DISPOSAL	22. Sewage disposal method: Public	✓		
SAFETY PRE-CAUTIONS	23. Life line in place/Separation of wading pool	✓		
	24. Warning/Safety sign posted in clearview of pool area	✓		
	25. First aid kits available & properly equipped	✓	(see addendum)	
	26. Emergency & lifesaving equipment in conspicuous place	✓		
	27. Emergency phone provided and hard wired	✓	(see addendum)	
	28. Gas cylinder precautions adequate	✓		
	29. Proper barrier around pool	✓	(see addendum)	
	30. Main drains properly covered and maintained	✓	(see addendum)	
OPERATOR AND RECORDS	31. Certified Pool Operator		(see addendum)	
	32. Lifeguard(s) (if provided) has proper certification	✓		
	33. Trained operator on duty	✓		
	34. Appropriate records on file	✓		
	35. Pool test kit(s) available and adequate for all necessary tests	✓		
	36. Other	✓		

**Remarks**  
Pool ok to Permit  
*SPA*

Date of Inspection  
01/31/2012

Discussed with (Signature & Title)  
  
Maintenance

Inspected by (Signature & Title)  
  
Environmental Health Specialist IV

**SATISFACTORY**

**UNSATISFACTORY**

**ENFORCEMENT**

None

Permit Suspended

Closed Voluntarily

Re-inspection needed within days

Hearing Requested/Recommended

Permit No. 106-P58

Expiration Date  
2011 12 31  
YY MM DD

Purpose:  
 1. Routine  
 2. Follow-up  
 3. Request  
 4. Complaint  
 5. Other

Length of Inspection  
732 Minutes

Pool Type:  
 Swimming/Pool  
 Spa  
 Special Purpose

Pool: Activity/Interactive/Wading Type: Pool

Required Turnover Rate 55.00 hours  
Type of Disinfectant Cal Hypo  
Required Concentration 6.0

Bather Load  
1 0

Laboratory Sample  
 1. None  
 2. Water  
 3. Other

Reason for Sample:

**MUSCOGEE COUNTY HEALTH DEPARTMENT  
 ENVIRONMENTAL HEALTH SECTION  
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

<b>Name of Facility</b> HILTON GARDEN INN SPA	<b>Address</b> 1500 BRADLEY LAKE BLVD	<b>City</b> COLUMBUS	<b>County</b>
<b>Operator</b> David Burris	<b>Address</b> 101 CASCADE RD	<b>City</b> COLUMBUS	<b>County</b>

Item Number	Notes
5	55 gpm
6	6.0
7	7.4
8	80
25	Located at Front desk
27	911
29	Must have room key to enter
30	VBG Act on file
31	David Burris