

**Georgia Department of Public Health
PUBLIC SWIMMING POOL INSPECTION RECORD**

OK to permit 2012

Name of Facility HOLIDAY INN EXPRESS SPA	Address 7336 BEAR LN	City COLUMBUS	County Muscogee	<input checked="" type="checkbox"/> SATISFACTORY <input type="checkbox"/> UNSATISFACTORY
Certified Pool Operator John Sackie	Address 7336 BEAR LN	City COLUMBUS	County	
<p>Deficiencies found on the inspection are marked with a (X). A check mark (✓) indicates satisfactory compliance, and (N/A) means non-applicable. *Indicates a substantial health hazard. Other items may be considered substantial health hazards depending on severity. The pool must be closed until substantial health hazards are corrected. One or more substantial health hazards violated, two or more other items violated or repeated violations will result in an unsatisfactory rating. An unsatisfactory rating may result in enforcement action.</p>				<p>ENFORCEMENT</p> <input checked="" type="checkbox"/> None <input type="checkbox"/> Permit Suspended <input type="checkbox"/> Closed Voluntarily <input type="checkbox"/> Re-inspection needed within days <input type="checkbox"/> Hearing Requested/Recommended
POOL WATER		X/✓	Notes	
	1. Water supply approved, adequate	✓		
	2. Depth properly marked	✓		
	3. Overflow facilities adequate	✓		
	4. Constant water level	✓		
	5. Turnover adequate	✓	(see addendum)	
	6. Disinfectant residual concentration 9	✓	(see addendum)	
	7. pH (7.2-7.8)	✓	(see addendum)	
	8. Total Alkalinity	X	(see addendum)	
	9. Calcium Hardness	✓	(see addendum)	
	10. Cyanuric Acid	✓	(see addendum)	
11. Clarity	✓			
PUMPING FILTRATION AND TREATMENT SYSTEM	12. Pump operating properly	✓		
	13. Filters functioning properly	✓		
	14. Hair & lint strainers functioning properly	✓		
	15. Skimmers/Gutters maintained & operating properly	✓		
	16. Chemical feeders operating properly	✓		
	17. Recirculation and filtration equipment readily accessible	✓		
	DECK AND POOL AREA	18. Pool & Decks clean and in good repair	✓	
19. Night lighting adequate		✓		
WATER AND FACILITIES	20. Hot & cold water under pressure	✓		
	21. Adequate toilet facilities & showers	✓		
SEWAGE DISPOSAL	22. Sewage disposal method: Public	✓		
SAFETY PRE-CAUTIONS	23. Life line in place/Separation of wading pool	✓		
	24. Warning/Safety sign posted in clearview of pool area	✓		
	25. First aid kits available & properly equipped	✓		
	26. Emergency & lifesaving equipment in conspicuous place	✓		
	27. Emergency phone provided and hard wired	✓	(see addendum)	
	28. Gas cylinder precautions adequate	✓	(see addendum)	
	29. Proper barrier around pool	✓		
	30. Main drains properly covered and maintained	✓		
	OPERATOR AND RECORDS	31. Certified Pool Operator		
32. Lifeguard(s) (if provided) has proper certification		✓	(see addendum)	
33. Trained operator on duty		✓		
34. Appropriate records on file		✓		
35. Pool test kit(s) available and adequate for all necessary tests		✓		
36. Other		✓		
Remarks				
Date of Inspection 01/31/2012	Discussed with (Signature & Title) <i>Rachel Sackie</i>		Inspected by (Signature & Title) <i>Wanda Bertwell</i> 1/31/12 Environmental Health Specialist IV	

**MUSCOGEE COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH SECTION
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

Name of Facility HOLIDAY INN EXPRESS SPA	Address 7336 BEAR LN	City COLUMBUS	County Muscogee
Operator John Sackie	Address 7336 BEAR LN	City COLUMBUS	County

Item Number	Notes
5	79gpm
6	9
7	7.6
8	200+
9	n/a
10	n/a
27	Using phone in weight room adjacent to spa or phone at pool right through the spa doorway to pool. Sign will be placed in spa room identifying phone sites.
28	n/a
32	n/a