

MUSCOGEE COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH SECTION
 PUBLIC SWIMMING POOL INSPECTION RECORD

Name of Facility Microtel Pool		Address 3930 St. Mary's RD	City COLUMBUS	County	✓SATISFACTORY UNSATISFACTORY		
Operator Southland Pool contract		Address 2255 Cumberland PKWY	City ATLANTA	County			
Deficiencies found on the inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance. Each blank under column (24-26) should be filled in with above symbols as appropriate.					ENFORCEMENT ✓ None Permit Suspended Closed Voluntarily Re-inspection needed within days Hearing Requested/Recommended Permit No. <div style="border: 1px solid black; padding: 2px; width: fit-content;">106-P86</div> Expiration Date <div style="border: 1px solid black; padding: 2px; display: flex; justify-content: space-around;"> 2012 12 31 </div> YR MO DA Purpose <div style="border: 1px solid black; padding: 2px; display: flex; align-items: center;"> 1 <div style="margin-left: 5px;"> 1. Routine 2. Re-inspection 3. Request 4. Complaint 5. Other </div> </div> Length of Inspection <u>00:30</u> Hours Pool Type: ✓ Swimming/Pool Spa Special Purpose Pool: Activity/Interactive/Wading Type: Pool Required Turnover Rate: <u>0.00</u> gpm Type of Disinfection: <u>Tri-clor</u> Required Concentration: <u>5.0</u> <div style="border: 1px solid black; padding: 2px; display: flex; justify-content: space-around; width: fit-content;"> 5 0 </div> Bather Load Purpose <div style="border: 1px solid black; padding: 2px; display: flex; align-items: center;"> <div style="margin-left: 5px;"> 1. None 2. Water 3. Other </div> </div> Reason for Sample:		
		Item No.	24-59	Notes			
POOL WATER	Type supply: Public						
	Water supply approved, adequate	1	✓				
	Depth properly marked	2	✓				
	Overflow facilities adequate	3	✓				
	Constant water level	4	✓				
	Turnover adequate	5	✓	(see addendum)			
	Disinfectant residual concentration	6	✓	(see addendum)			
	pH (7.2-7.8)	7	✓	(see addendum)			
	Total Alkalinity	8	✓	(see addendum)			
	Calcium Hardness	9	✓				
	Cyanuric Acid	10	✓				
Clarity	11	✓					
PUMPING FILTRATION AND TREATMENT SYSTEM	Pump operating properly	12	✓				
	Filters functioning properly	13	✓				
	Hair & lint strainers functioning properly	14	✓				
	Skimmers/Gutters maintained & operating properly	15	✓				
	Chemical feeders operating properly	16	✓				
	Recirculation and filtration equipment readily accessible	17	✓				
DECK AND POOL AREA	Pool & Decks clean and in good repair	18	✓				
	Night lighting adequate	19	✓				
	Hot & cold water under pressure	20	✓				
WATER AND FACILITIES	Adequate toilet facilities & showers	21	✓	(see addendum)			
	SEWAGE DISPOSAL	Sewage disposal method: Public	22	✓			
SAFETY PRE-CAUTIONS		Life line in place/Separation of wading pool	23	✓			
		Warning/Safety sign posted in clearview of pool area	24	✓			
		First aid kits available & properly equipped	25	✓		(see addendum)	
		Emergency & lifesaving equipment in conspicuous place	26	✓			
		Emergency phone provided and hard wired	27	✓		(see addendum)	
		Gas cylinder precautions adequate	28	✓			
		Proper barrier around pool	29	✓			
		Main drains properly covered and maintained	30	✓			
		OPERATOR AND RECORDS	Certified Pool Operator	31			(see addendum)
			Lifeguard(s) (if provided) has proper certification	32		✓	
Trained operator on duty	33		✓	(see addendum)			
Appropriate records on file	34		✓				
Pool test kit(s) available and adequate for all necessary tests	35		✓				
Other	36		✓				
Gauge Readings:		Laboratory Results:					
Influent Pressure	<u>0.00</u> psi	Alkalinity	<u>0.00</u> ppm				
Effluent Pressure	<u>0.00</u> psi	Coliform Count	<u>0.00</u>				
Flow Rate Main Pool	<u>0.00</u> gpm	Plate Count	<u>0.00</u>				
Flow Rate Wading Pool	<u>0.00</u> gpm						
Name of Bactericide In Use: <u>Tri-clor</u>		Rate	<u>0.00</u> ppm				
Name of Stabilizer In Use:		Rate	<u>0.00</u> ppm				
Name of Filter System In Use:							
Algae Control Measures:							
Remarks							
Date of Inspection	Discussed with (Signature)	Inspected by (Signature)					
09/27/2011	Johnny Johnson Title: Maintance	Trina Macon Title: Environmental Health Specialist IV					

**MUSCOGEE COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH SECTION
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

Name of Facility		Address	City	County
Microtel Pool		3930 St. Mary's RD	COLUMBUS	
Operator		Address	City	County
Southland Pool contract		2255 Cumberland PKWY	ATLANTA	
Item Number	Notes			
5	55 gpm			
6	5.0			
7	7.8			
8	160			
21	In lobby and in rooms			
25	Front desk			
27	911			
31	Southland pools contract			
33	Johnny Johnson			