

Georgia Department of Human Resources - Division of Public Health  
TOURISTS ACCOMMODATION INSPECTION RECORD

Name of Accommodation <b>COLONY INN</b>	Address <b>4300 VICTORY DR</b>	City <b>COLUMBUS</b>	County <b>Muscogee</b>
--------------------------------------------	-----------------------------------	-------------------------	---------------------------

Deficiencies found during inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance.

	No.	Item Description	Eval. Pts.	X ✓	Notes	Score
<b>Water Supply</b>	1.	Adequate, approved, no cross-connection	6	✓		<b>98</b>
	2.	Trailer water tank hose properly used & stored	1	✓		
	3.	Cups, glasses & multiuse utensils washed, rinsed & sanitized after each occupancy or single service provided	4	✓		
	4.	Drinking founts of approved design	1	✓		
	5.	Ice from an approved source stored and handled properly	2	✓		
<b>Toilet Facilities</b>	6.	Toilet facilities provided	5	✓		
	7.	Rooms, fixtures clean & in good repair	2	✓		
	8.	Well lighted, ventilated	2	✓		
	9.	Hot & cold water under pressure, soap & individual towels, receptacles	2	✓		
	10.	Central toilet facilities, separate for each sex, provided within 200 feet of each dwelling unit served	3	✓		
<b>Sewers</b>	11.	Sewers & connections approved	2	✓		
<b>Sewage Disposal</b>	12.	Method Public Sewer	Public Sewer			
	12.	Sewage & other liquid waste disposed of by an approved manner	4	✓		
<b>Plumbing</b>	13.	Plumbing properly installed with no back siphonage, good repair	4	✓		
<b>Refuse Disposal</b>	14.	Containers adequate, approved, properly located	4	✓		
	15.	Approved collection & disposal	4	✓		
<b>Insect/Rodent Control</b>	16.	Dwelling units effectively screened or other means for excluding vermin	2	X	(see addendum)	
	17.	Vermin effectively controlled	2	✓		
<b>Housing</b>	18.	Clean, structurally sound, good repair	5	✓		
	19.	Well lighted, ventilated	1	✓		
	20.	Furnishings clean & in good repair	4	✓		
	21.	Bed clothing clean, linens replaced daily unless written notice is given to occupant	4	✓		
<b>Heating and Fire Safety</b>	22.	Type Individual Other	Individual Other			
	22.	All gas appliances properly vented to...?	6	✓		
	23.	Natural gas equipment equipped with automatic safety pilot, liquefied petroleum appliances with 100% safety pilot	6	✓		
	24.	Gas water heaters properly located and vented	1	✓		
	25.	Smoke detectors & fire extinguishers installed & operational	2	✓		
<b>Food Service</b>	26.	Type				
	26.	In compliance with applicable rules	8	✓		
<b>Laundry Rooms</b>	27.	Separate, structurally sound, clean, good repair	2	✓		
	28.	Hot & cold water under pressure, adequate light & ventilation	2	✓		
<b>Grounds</b>	29.	Well drained, clean, maintained	1	✓		
	30.	Trailers properly spaced and marked 15 feet between trailers & property lines, 10 feet between trailers and internal driveways, abuts on drives 20 feet or wider	1	✓		
	31.	Grounded & weatherproof electrical outlets at each trailer space; power lines underground or suspended or at least 18 feet above ground	1	✓		
	32.	Swimming pool and spa in compliance	1	✓		
<b>Employee Hygeine</b>	33.	Good personal hygiene, no communicable disease	4	✓		
<b>Permit</b>	34.	Permit displayed, current inspection report posted	1	✓		

County Code  
**106**

Permit Number  
**T106-022**

# of Units  
**66**

Purpose  
**1**

1. Routine  
2. Follow up  
3. Request  
4. Complaint  
9. Other

Inspection Time  
**16:05**

Disposition  
**1**

1. Permit Issued  
2. Permit Denied  
3. Enforcement Action Recommended

Additional comments 25,37,35,74		* Place Appropriate Number in Block	
Date of Inspection  10/19/2010 Next Inspection Due 06/30/2011	Discussed with (Signature)  Ronnie Williams  Title: Mgr	Inspected by (Signature)  Jason Long  Title: Environmental Health Specialist II	

Georgia Department of Human Resources - Division of Public Health  
TOURISTS ACCOMMODATION INSPECTION RECORD

Name of Accommodation	Address	City	County
COLONY INN	4300 VICTORY DR	COLUMBUS	Muscogee
Number	Notes		
1:	n/a		
2:	n/a		
15:	Waste Management		
16:	No screens on windows		
17:	In house		
24:	n/a		
30:	n/a		
31:	n/a		
32:	n/a		