

**Georgia Department of Human Resources - Division of Public Health
TOURISTS ACCOMMODATION INSPECTION RECORD**

Name of Accommodation HOMETOWNE SUITES	Address 6040 KNOLOGY WAY	City COLUMBUS	County Muscogee
--	------------------------------------	-------------------------	---------------------------

Deficiencies found during inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance.

	No. Item Description	Eval. Pts.	X ✓	Notes	Score
Water Supply	1. Adequate, approved, no cross-connection	6	✓		100
	2. Trailer water tank hose properly used & stored	1	✓		
	3. Cups, glasses & multiuse utensils washed, rinsed & sanitized after each occupancy or single service provided	4	✓		
	4. Drinking fountains of approved design	1	✓		
	5. Ice from an approved source stored and handled properly	2	✓		
Toilet Facilities	6. Toilet facilities provided	5	✓		
	7. Rooms, fixtures clean & in good repair	2	✓		
	8. Well lighted, ventilated	2	✓		
	9. Hot & cold water under pressure, soap & individual towels, receptacles	2	✓		
	10. Central toilet facilities, separate for each sex, provided within 200 feet of each dwelling unit served	3	✓		
Sewers	11. Sewers & connections approved	2	✓		
Sewage Disposal	12. Method Public Sewer	Public Sewer			
	12. Sewage & other liquid waste disposed of by an approved manner	4	✓		
Plumbing	13. Plumbing properly installed with no back siphonage, good repair	4	✓		
Refuse Disposal	14. Containers adequate, approved, properly located	4	✓		
	15. Approved collection & disposal	4	✓		
Insect/Rodent Control	16. Dwelling units effectively screened or other means for excluding vermin	2	✓		
	17. Vermin effectively controlled	2	✓		
Housing	18. Clean, structurally sound, good repair	5	✓		
	19. Well lighted, ventilated	1	✓		
	20. Furnishings clean & in good repair	4	✓		
	21. Bed clothing clean, linens replaced daily unless written notice is given to occupant	4	✓		
Heating and Fire Safety	22. Type Individual Other	Individual Other			
	22. All gas appliances properly vented to...?	6	✓		
	23. Natural gas equipment equipped with automatic safety pilot, liquefied petroleum appliances with 100% safety pilot	6	✓		
	24. Gas water heaters properly located and vented	1	✓		
	25. Smoke detectors & fire extinguishers installed & operational	2	✓		
Food Service	26. Type Continental breakfast only	Continental breakfast only			
	26. In compliance with applicable rules	8	✓		
Laundry Rooms	27. Separate, structurally sound, clean, good repair	2	✓		
	28. Hot & cold water under pressure, adequate light & ventilation	2	✓		
Grounds	29. Well drained, clean, maintained	1	✓		
	30. Trailers properly spaced and marked 15 feet between trailers & property lines, 10 feet between trailers and internal driveways, abuts on drives 20 feet or wider	1	✓		
	31. Grounded & weatherproof electrical outlets at each trailer space; power lines underground or suspended or at least 18 feet above ground	1	✓		
	32. Swimming pool and spa in compliance	1	✓		
Employee Hygiene	33. Good personal hygiene, no communicable disease	4	✓		
Permit	34. Permit displayed, current inspection report posted	1	✓		

County Code
106

Permit Number
T106-874

of Units
77

Purpose
1 1. Routine
2. Follow up
3. Request
4. Complaint
9. Other

Inspection Time
13:00

Disposition
1
1. Permit Issued
2. Permit Denied
3. Enforcement Action Recommended

Additional comments: Rooms inspected: 102, 105, 117, 200, 221, 312, 300
Date of Inspection: 10/24/2011
Discussed with (Signature): *Erika Randall*
Inspected by (Signature): *Ashley Basset*
Next Inspection Due: 06/30/2012
Title: *Guest Services Rep.*
Title: Environmental Health Specialist I